

LOCATION 1818 abbotstford ct. CITY Gastonia
BETWEEN old stone Ln. STREET & Norseman ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>114'</u>	<u>4-11-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>74'</u>	<u>"</u>		

ENTERS 1818 BRANCHED INTO 0
TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 156' south


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody
center of old stone Ln.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3' FT 0" IN LOCATION 16' West of center of abbotstford ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 0254982

REMARKS New 3/4" P. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>