

LOCATION 2420 Amber Crest DR CITY Castroville

BETWEEN Myrtle School Rd. STREET & Red Tip STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	103'	11-20-86		
MAIN TO PROP. LINE	3/4"	P	25'			
PROP. LINE TO BLDG.	3/4"	P	78'			

ENTERS: 2420 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 800' W. of center of

Myrtle School Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Harksheth

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1967

DEPTH: 3 FT. 0 IN. LOCATION 6' S. of center of Amber Crest DR.

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # 662674

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY