

LOCATION 1819 Abbotts Ford Ct. CITY GASTONIA
 BETWEEN Norsemen Ct. STREET & End of Culdesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>80'</u>	<u>1-14-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>10'</u>			
PROP LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>70'</u>			

ENTERS 1819 BRANCHED INTO 0
 TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 23' W of Coy Norsemen Ct.

PRESSURE TEST 100 PSI FOR 1/4 HRS BY RL
 MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
 DEPTH 3 FT 0 IN LOCATION 20' N of Coy Abbotts Ford Ct.

A P/S READING PLASTIC N/A TOTAL ANODES 1# 0 17# 0 LR # 00020521

REMARKS _____

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

