


LOCATION 2754 Ambercrest Dr CITY Oaktonia  
BETWEEN Fawnbrook STREET & Antlers. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	518	P	110'	9-19-02		
MAIN TO PROP LINE	518	P	40'			
PROP LINE TO BLDG	518	P	70'			

ENTERS \_\_\_\_\_ BRANCHED INTO \_\_\_\_\_  
TAP SIZE 3/4 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 20' S. of Ambercrest  
& 90' W. of Antlers Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY CR  
MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 2002  
DEPTH 3 FT 6 IN LOCATION 20' S. of Ambercrest Dr.

"A" P/S READING N/A TOTAL ANODES 1# - 17# - LR # -  
REMARKS RAN new service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P-Riser
P/S Pipeline Lead - White Existing Main	E	