

LOCATION 2755 Ambercrest Dr. CITY Crofton

BETWEEN ANTHUS CT STREET & ELKHORN LN STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>50"</u>	<u>P</u>	<u>54'</u>	<u>10-21-02</u>		
MAIN TO PROP LINE	<u>50"</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>50"</u>	<u>P</u>	<u>49'</u>			

ENTERS 2755 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 100 PSI INCHES W C LOCATION 13' W. of park at ANTHUS CT


PRESSURE TEST @ 100 PSI FOR 14 HRS BY S.H.

MAIN SIZE 2" C I  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 2007

DEPTH 3 FT 0 IN LOCATION 10' S. of park at Ambercrest DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 312801

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	