

LOCATION 2772 Amburst DR CITY CASTON, W

BETWEEN Aukers CT STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>53'</u>	<u>10-21-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>23'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>30'</u>			

ENTERS 2772 BRANCHED INTO 2766

TAP SIZE 3/4" PRESSURE 600 PSI INCHES W C LOCATION 93' W. of center of Amburst DR

PRESSURE TEST @ 600 PSI FOR 1/4 HRS BY S.G.

MAIN-SIZE 2 1/2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2002

DEPTH. 2 FT 0 IN LOCATION 212' SW. of center of Aukers CT

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 312032

REMARKS.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

