

LOCATION 1435 Anderson St. CITY Gastonia  
BETWEEN May Ct. STREET & Wellons Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	92'	9-14-00		
MAIN TO PROP. LINE	3/4"	P	42'			
PROP. LINE TO BLDG.	3/4"	P	50'			

ENTERS. Same BRANCHED INTO:

TAP SIZE: 1/4" PRESSURE 60 PSI INCHES W C LOCATION 23' East of

Anderson St + 134' South of May Ct.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY B. BAIRD

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1965

DEPTH: 3 FT 6 IN LOCATION 23' East of Anderson St.

"A" P/S READING .95 TOTAL ANODES 1#        17#        L.R. # 00831079

REMARKS. New Plastic Service.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	p. Riser
P/S Pipeline Lead - White Existing Main	E	

