


LOCATION 5417 Anderson Ct.CITY CANTONIABETWEEN Cramerton Rd.STREET & Anderson Ct.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>111'</u>	<u>3-2-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>101'</u>			

ENTERS: 5417BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 PSI 1 INCHES W.C. LOCATION 111' E of CofPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RLMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 4 FT. 0 IN. LOCATION 19' E of Cof Anderson Ct."A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 117998

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY