

LOCATION 1834 Abbotts Ford Ct. CITY Easton, Va
 BETWEEN Abbotts Ford Ct. STREET & Norsemen Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>50'</u>	<u>1-14-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>45'</u>			

ENTERS: _____ BRANCHED INTO _____
 TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 135' S of Cap Abbotts Ford Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2 1/2 C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION 45' W of Cap Norsemen Ct

A P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # 00018647

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red	S	<u>Riser</u>
New Service		<u>Plastic</u>
P/S Pipeline Lead - White	E	
Existing Main		