

LOCATION 2423 Anderson ex CITY Gastonia

BETWEEN Old Course dr STREET & Old Course dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	100'	11-5-98		
MAIN TO PROP. LINE	1"	1"	6'			
PROP. LINE TO BLDG.	1"	1"	94'			

ENTERS: 2423 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE — PSI — INCHES W.C. LOCATION 18' S. of C of

Anderson


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION —

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY