

LOCATION 2012 Andika Ln. CITY Gastonia

BETWEEN Courtland DR. STREET & Redbud DR. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	578'	P	145'	1-15-02		
MAIN TO PROP. LINE	578'	P	50'			
PROP. LINE TO BLDG	578'	P	95'			

ENTERS 2012 BRANCHED INTO

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 363' W. of center of Courtland DR.

PRESSURE TEST @ 160 PSI FOR 1 1/4 HRS BY S.L.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 23' S. of center of

"A" P/S READING 1.5 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

