


LOCATION 2905 Angela Ct.CITY GASTONIABETWEEN ERICA LN.STREET & End of Culdesack

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>135'</u>	<u>12-14-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>125'</u>			

ENTERS: 2905BRANCHED INTO: 0TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 262' E of C of Erica Ln.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RLMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1986DEPTH: _____ FT. _____ IN. LOCATION 52' N of C of Angela Ct."A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 214707

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY