

LOCATION 1842 Abbottsford Ct CITY Boston

BETWEEN Norseman Ct STREET & Put-De-Spe STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>118'</u>	<u>11-6-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>73'</u>			

ENTERS 1842 BRANCHED INTO.

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W/C LOCATION 128' W. of center of Norseman Ct


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.O.

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 18' N. of center of Abbottsford Ct

"A" P/S READING P TOTAL ANODES 1# 2 17# 0 LR # 1003273

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	