

LOCATION 110 ANN St. CITY Gastonia

BETWEEN Warren Ave. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>33'</u>			<u>6-9-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>27'</u>			

ENTERS: SAME BRANCHED INTO: 108 ANN St.

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 89' From @ of

Warren Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY W.H.f.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION Westside of ANN St.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY