

LOCATION 116 Ann St. CITY Gastonia  
BETWEEN Warren Ave. STREET & Craig St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>31'</u>		<u>6-</u>	<u>10-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>9'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>22'</u>			


ENTERS: SAME BRANCHED INTO: 118 Ann St.  
TAP SIZE: 3/4" PRESSURE 60 PSI        INCHES W.C. LOCATION 169' From @ of  
Warren Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY A.H.F.  
MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 1 IN. LOCATION Westside of Ann St.

"A" P/S READING P. TOTAL ANODES 1#        17#        L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY