

LOCATION 118 Ann st. CITY Gastonia

BETWEEN Warren Ave. STREET & Craig st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	109'		6-	10-97
MAIN TO PROP. LINE	"	"	35'			
PROP. LINE TO BLDG.	"	"	74'			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 170' From @ OF

Warren Ave.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DHE

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION westside of Ann st.

"A" P/S READING 0 TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY