


LOCATION 200 ANNDALE AVECITY Gastonia

BETWEEN _____ STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>45'</u>	<u>12-6-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>59'</u>			

ENTERS 200 BRANCHED INTO _____TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION 15' S. of 304PRESSURE TEST @ 100 PSI FOR 1 1/2 HRS BY JPP Ann DaleMAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1972DEPTH 3 FT 0 IN LOCATION _____"A" P/S READING 1.20 TOTAL ANODES 1# _____ 17# _____ LR # _____REMARKS: _____

_____

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	