

LOCATION 409 B Apple st CITY GASTONIA
 BETWEEN Cedar STREET & Elm STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>107'</u>	<u>3-12-99</u>	<u>3-12-99</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>20'</u>		<u>or 8-</u>	
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>87'</u>		<u>Inst. 8-26-63</u>	

ENTERS: 409 BRANCHED INTO
 TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 287' N of Cedar


PRESSURE TEST 100 PSI FOR 24 HRS BY M. PARKER

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999

DEPTH: 3 FT 0 IN LOCATION 67' W OF Apple

"A" P/S READING P TOTAL ANODES 1# 17# I.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-RIDER</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	