

LOCATION 411 Apple St CITY Canton  
BETWEEN Elm STREET & Cedar STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>66'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>			<u>1-25-59</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56'</u>			

ENTERS: 408 BRANCHED INTO: 411

TAP SIZE: 3/4 Sec. PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ED

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1963

DEPTH: 2 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING 1.1 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>DIAGN</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY