

LOCATION 603 N. Apple St. CITY GASTON, IA

BETWEEN Elm St STREET & Hemlock Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>36'</u>	<u>10-5-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>31'</u>			

ENTERS: 603 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 200' S. of center of

Hemlock Ave.


PRESSURE TEST: @ 160 PSI FOR 1/4 HRS. BY S. H. K. S. S. S. S.

MAIN-SIZE 1 1/2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1954

DEPTH: 3 FT. 0 IN. LOCATION 7' W. of center of N. Apple St.

"A" P/S READING .6 TOTAL ANODES 1# 0 17# 1 L.R. # 205653C

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY