

LOCATION 705 & 711 APPLE BLOSSOM CIRCLE CITY GAST.

BETWEEN ESSEX STREET & NO. OUTLET STREET

| | SIZE | TYPE | 705 LENGTH 711 | INSTALLED | RETIRED | RENEWED |
|---------------------|-----------------|------|----------------|-----------|-------------|---------|
| MAIN TO BLDG. | $3\frac{1}{4}"$ | P | 73 84 | | 9 - 20 - 96 | |
| MAIN TO PROP. LINE | " | " | 0 5 | | | |
| PROP. LINE TO BLDG. | " | " | 73 79 | | | |

ENTERS: 711 BRANCHED INTO: 705

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION S. of 705
E. of 711


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GL

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION S. of Apple Blossom Circle

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



| Test Station | | |
|---|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | P |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY