

LOCATION Gastex Inc Aberdeen Blvd CITY GASTONIA  
BETWEEN Scaly Bark Rd STREET & \_\_\_\_\_ STREET

	SIZE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	111'	11/13/79		
MAIN TO CURB	3/4"	11'			
CURB TO BLDG.	3/4"	100'			

ENTERS: Gastex Inc BRANCHED INTO:  
TAP SIZE: 3/8 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION West side of Gastex

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Johansen  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ YEAR INSTALLED 1979  
DEPTH: 2 Ft. 6 In. LOCATION South side of Aberdeen Blvd

TOTAL ANODES 1# 0 17# 0 TOTAL TEST STATIONS 10

REMARKS:

ENG. DEPT. USE ONLY