

LOCATION 3539 ARAGLIN Dr. CITY Gastonia
BETWEEN Ashbourne Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>88'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>7-27-01</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>28'</u>			

ENTERS 3539 BRANCHED INTO 0
TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION _____


PRESSURE TEST @ 100 PSI FOR 114 HRS BY ED

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 2001

DEPTH 4 FT 6 IN LOCATION _____

"A" P/S READING P TOTAL ANODES I# 17# LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	