

LOCATION 3547 Araglin Dr. CITY GASTONIA  
 BETWEEN Ashbourne LN. STREET & End of culdesack STREET  


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>115'</u>	<u>9-28-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>105'</u>			

 ENTERS 3547 BRANCHED INTO 0  
 TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 195' W of Cy Ashbourne LN.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL  
 MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999  
 DEPTH 3 FT 0 IN LOCATION 26' S of Cy Araglin Dr.

\*A\* P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	Plastic