

LOCATION 2500 Arbroath Trnce CITY GASTONIA
BETWEEN chevit Ln STREET & Cal-d- Snc STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4'</u>	<u>Plastic</u>	<u>151'</u>	<u>11/26/07</u>		
MAIN TO PROP. LINE	<u>3/4'</u>		<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4'</u>		<u>139'</u>			

ENTERS: 2500 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION East side of 2500


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION West side of Arbroath Trnce

"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 793655

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY