

LOCATION 1800 Archwood Dr. CITY Gastonia

BETWEEN Linwood STREET & Mary Lee STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>202'</u>		<u>8-9</u>	<u>93</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>		<u>200' of 1" BARE</u>	
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>162'</u>			

ENTERS: 1800 Archwood Dr. BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION N. Side of 1800


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GK

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. _____ In. LOCATION S. Side of Archwood Dr.

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY