

LOCATION 1833 & 1841 Archwood Dr. CITY Gastonia
 BETWEEN Mary Lee STREET & Linwood STREET


	SIZE	TYPE	1833 LENGTH	1841	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	143'	76'		8. 10. 93	
MAIN TO PROP. LINE	"	"	5'	10'		1833 ARCHWOOD DR. 80' of 3/4" C&W	
PROP. LINE TO BLDG.	"	"	138'	66'		1841 ARCHWOOD DR. 90' of 1" BARE	

 ENTERS: 1833 Archwood Dr. BRANCHED INTO: 1841 Archwood Dr.
 TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION S. Side of 1833 & 1841

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GK
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1993
 DEPTH: 3 Ft. _____ In. LOCATION S. Side of Archwood Dr.

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY