

LOCATION 1835 ~~1385~~ + 184 / Arkray St. CITY GASTONIA

BETWEEN Bond STREET & Brown STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3' used to tie over</u>	<u>12-16-91</u>		
MAIN TO PROP. LINE			<u>split Services</u>			
PROP. LINE TO BLDG.						

ENTERS: 1835 BRANCHED INTO: 1841

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 243 West of center of Brown


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1991

DEPTH: 3 Ft. _____ In. LOCATION 17 North of center of Arkray

"A" P/S READING _____ TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>1.0</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY