

LOCATION 1846 ArkRAY St.

CITY GASTONIA

BETWEEN Brown St.

STREET & Bessemer City Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	12-17-91	Tied over 52' of Existing	
MAIN TO PROP. LINE					CTW to 4" Plastic Main	
PROP. LINE TO BLDG.						

ENTERS: 1846 ArkRAY St.

BRANCHED INTO: 0

TAP SIZE: 1/2

PRESSURE 60 P.S.I.

INCHES W.C.

LOCATION 360' S of C of Brown St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. 0 In. LOCATION 16' W of C of ArkRAY St.


"A" P/S READING 1.2

TOTAL ANODES 1# ☒ 17#

L.R. #

REMARKS:

Tied Tracer wire off at Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1.2
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY