

LOCATION 1854 ArkwayCITY GastoniaBETWEEN BrownSTREET & Bond

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3'</u>	<u>12-20-91</u>		
MAIN TO PROP. LINE		<u>CW tied over to Plastic</u>				
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 284 East of  
center of Bond


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 16 North of center of Arkway

"A" P/S READING .7 TOTAL ANODES 1# 1 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RS</u>	<u>1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY