

LOCATION 1855 Ashray St CITY Easton
BETWEEN Bond STREET & Brown STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>105</u>	<u>5-3-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>35</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>70</u>			

ENTERS: 1855 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Sidehouse


PRESSURE TEST: @ 100 psi For 1 1/2 Hrs. By Bond

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 2 Ft. 6 In. LOCATION 15' W of C. 1st

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # 164481

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY