

LOCATION 2320 Armstrong Circle CITY CATHONIA
BETWEEN S. New Hope Rd. STREET & Armstrong Circle STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>130'</u>	<u>7-8-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>115'</u>			

ENTERS: 2320

BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 335' E of Cof S. New Hope Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1963

DEPTH: 3 FT. 0 IN. LOCATION 23' N of Cof Armstrong Circle

"A" P/S READING 90 TOTAL ANODES 1# 0 17# 0 L.R. # 356687

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY