

LOCATION 2326 Armstrong Cir CITY GASTONIA
BETWEEN S. New Hope Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	96'	3-24-95		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	86'			

ENTERS: 2326 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 420' E. of center of
S. New Hope Rd.


PRESSURE TEST: @ 160 psi For 1/4 Hrs. By S. Whiffle

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1960

DEPTH: 3 Ft. In. LOCATION 17' N. of center of Armstrong Cir

"A" P/S READING .6 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY