

LOCATION 110 ARMSTRONG ST CITY Gastonia
BETWEEN OTARR STREET & AIRLINE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	23'	9-28-99		
MAIN TO PROP. LINE	"	"	6'			
PROP. LINE TO BLDG	"	"	17'			


ENTERS. 110 BRANCHED INTO
TAP SIZE 1/2 PRESSURE PSI INCHES W.C. LOCATION 12' E. of cot

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Armstrong
MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>ER</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	