

LOCATION 1604 Armstrong Ford Rd. CITY Gastonia

BETWEEN CHST ST STREET & OAK ST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>153'</u>	<u>6-12-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>60'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>93'</u>			

ENTERS: 1604 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 94' w. of center of

OAK ST.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hunt-Steffy

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 24' S. of center of Armstrong Ford Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 304593

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY