

LOCATION 1608 Armstrong Ford Rd. CITY GASTONIA  
BETWEEN Oak St. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>110'</u>	<u>10-17-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>70'</u>			

ENTERS. Same BRANCHED INTO

TAP SIZE. 1/2 PRESSURE 60' PSI \_\_\_\_\_ INCHES W.C. LOCATION 20' South of

Armstrong Ford Rd. & 229' west of Oak St.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard


MAIN SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3 FT 6 IN LOCATION 20' South of Armstrong Ford Rd.

"A" P/S READING Plastic TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # 00960859

REMARKS.

New Plastic Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	