

LOCATION 1612 ARMSTRONG FORD Rd CITY Gastonia
BETWEEN CREST STREET & OAK STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>118'</u>	<u>10-5-99</u>		
MAIN TO PROP LINE	<u>"</u>	<u>"</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>"</u>	<u>"</u>	<u>78'</u>			

ENTERS 1612 BRANCHED INTO
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W/C LOCATION 20' W. of Cap

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Armstrong Ford
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997
DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>I</u>	