

LOCATION 1619 Armstrong Ford Rd. CITY DASTONIA
BETWEEN Crest St. STREET & DAK St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>98'</u>	<u>4-1-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>83'</u>			

ENTERS: 1619 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 120' E of Crest St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 4 FT. 0 IN. LOCATION 19' S of C of upper Armstrong Ford Rd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 115574

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		