


LOCATION		1620 Armstrong Ford Rd		CITY		Castonia	
BETWEEN		Crest St.		STREET &		STREET	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED	
MAIN TO BLDG	8 1/2'	P	95'	1-13-03			
MAIN TO PROP LINE	5 1/2'	P	40'				
PROP LINE TO BLDG	5 1/2'	P	55'				
ENTERS		1620		BRANCHED INTO			
TAP SIZE	3/4"	PRESSURE	60	PSI	INCHES W C	LOCATION 172' E of center of Crest St.	
PRESSURE TEST @		100		PSI	FOR	1 1/2 HRS BY S.H.	
MAIN-SIZE	4"	C I		BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED 1996
DEPTH	3 FT	0 IN	LOCATION 18' S. of center of Armstrong Ford Rd				
"A" P/S READING		P		TOTAL ANODES 1#		0	17# 0
				LR #		4835	
REMARKS							



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	