

LOCATION 1633 Armstrong Ford Rd. CITY Gastonia
BETWEEN Crest STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>58'</u>	<u>9-9-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>53'</u>			

ENTERS 1633 BRANCHED INTO P
TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# 17# LR #

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plashe</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	