

LOCATION 801 Adams Ct CITY Gardena
BETWEEN Adams Ct STREET & Weldar STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>43'</u>			<u>9-93</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>		<u>40' of 1" BARE</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>13'</u>			

ENTERS: 801 Adams Ct BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE: 60 P.S.I. _____ INCHES W.C. LOCATION 60' W of Adams Ct

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Brown
MAIN-SIZE 2 1/2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
DEPTH: 3 Ft. 0 In. LOCATION 14' N of 7th Ave

"A" P/S READING 1 TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>10</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>1</u>

ENG. DEPT. USE ONLY