

LOCATION 501 ARMSTRONG PK Rd CITY Gastonia
BETWEEN ARMSTRONG PK Rd STREET & Ruby STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>108.</u>	<u>10-20-99</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>"</u>	<u>35.</u>			
PROP LINE TO BLDG	<u>1"</u>	<u>"</u>	<u>73.</u>			

ENTERS 501 BRANCHED INTO
TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W/C LOCATION 15' N. of Cot


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY GP ctub

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1969

DEPTH 2 FT 6 IN LOCATION _____

"A" P/S READING 1.10 TOTAL ANODES 1# 17 LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	