

LOCATION 803 Adams ct

CITY Gastonia

BETWEEN 7th Ave

STREET &

Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	80'		9	9-93
MAIN TO PROP. LINE	3/4	P	16'		70' of 3/4" CFW	
PROP. LINE TO BLDG.	3/4	P	64'			

ENTERS: 803 Adams ct

BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 68' S of 7th Ave


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Moore

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC — YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 7' E of Adams ct

"A" P/S READING P TOTAL ANODES 1* — 17* — L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead — Red New Service	S	P
P/S Pipeline Lead — White Existing Main	E	

ENG. DEPT. USE ONLY