

LOCATION 2608 Armstrong Park Rd.

CITY Gastonia

BETWEEN Thomas Trail

STREET & Ruby

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	127 3'	4-16-94	tieover	to New 2" Plastic
MAIN TO PROP. LINE			127' Existing	3/4 Plastic		
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 163 North of

Armstrong Park Dr


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. In. LOCATION 10' West of center of Thomas Trail

"A" P/S READING P. TOTAL ANODES 1* 17* L.R. #

REMARKS: Tracer wire Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY