

LOCATION 2702 Armstrong Park Rd

CITY Gastonia

BETWEEN Club Dr.

STREET &amp; Armstrong Park Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'		Tied over	148' of EXT
MAIN TO PROP. LINE				8-7-23-93	3/4 G/W Ser.	to EXT 2"
PROP. LINE TO BLDG.					Plastic MAIN	

ENTERS: 2703

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 14' E of Cop Rd 1/1  
136' N of Cop Armstrong Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By EP

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING PS TOTAL ANODES 1\* 17\* 0 L.R. #

REMARKS: Tracer wire tied off at Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S Riser	1.0
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY