

LOCATION 308 Art Hur CITY Easton
BETWEEN S. York Rd. STREET & CLYDE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>62'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>7</u>		<u>9-26-96</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>55'</u>			

ENTERS: 308 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY EP

MAIN-SIZE 2" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING .6 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: NO Anode Installed
Bare main to be Retired & Renewed

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>PLASTIC</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		