

LOCATION 312 AUTHUR AVECITY GASTONIABETWEEN YORK RDSTREET & CLYDE ST.

STREET


	SIZE	TYPE	312 LENGTH	310	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PL</u>	<u>108'</u>	<u>26' Tee To Meter</u>		<u>3-25-98</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>36'</u>	<u>—</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>72'</u>	<u>—</u>			

ENTERS: 312BRANCHED INTO: 310TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W.C.

LOCATION 360' E FROM 9/0F YORKPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BBMAIN-SIZE 2"C.I. —BARE STEEL —COATED STEEL —PLASTIC ✓YEAR INSTALLED 1998DEPTH: 3 FT. 0 IN.LOCATION 17' S FROM CENTER OF AUTHUR"A" P/S READING PLTOTAL ANODES 1# — 17# —L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RI SER</u>	<u>PL</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY