

LOCATION 526 W Airline Ave CITY East  
BETWEEN Boyce STREET & Morris STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	72		4 - 4	- 96
MAIN TO PROP. LINE	"	"	40			
PROP. LINE TO BLDG.	"	"	32			

ENTERS: 526 W. Airline BRANCHED INTO:  
TAP SIZE: 3/4 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION N. side of 526

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GJK  
MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 96  
DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION W. side of N. Morris

"A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY