

'LOCATION 602 W. Airline Ave. CITY Yost.

BETWEEN Morris STREET & Cherry STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>12'</u>		<u>4 - 4</u>	<u>-96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>8'</u>			

ENTERS: 602 W. Airline BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION N. of 602


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GK

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION W. Side of N. Morris

"A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY