

LOCATION 610 E. Airline Ave. CITY GASTONIA
BETWEEN Rhyme St. STREET @ Avon St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>115'</u>	<u>6-24-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>18'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>97'</u>			

ENTERS: 610 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 225' w of C of Rhyme St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 12" C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1990
DEPTH: 4 Ft. 6 In. LOCATION 39' S of C of E. Airline Ave.

"A" P/S READING 1.5 TOTAL ANODES 1* — 17* — L.R. # 0299492

REMARKS: New 3/4 Plastic Service OFF Steel MAIN



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY